



July 2, 2010

VILLAGE OF VIOLA
VIOLA STP UPGRADE
IEPA PROJECT #L-17-292900
2010

BID DATE: 11:00 A.M., JULY 7, 2010

ADDENDUM #2

TO: All Plan Holders:

The following clarification shall apply to the captioned project:

The project includes the construction of a temporary treatment cell and associated modifications of the existing plant inlet piping. It is assumed that at a minimum, temporary bypass pumping will be required for the modifications to the existing inlet pipe to the existing facultative lagoon for the proposed temporary treatment cell construction. The Bidders must assume that at a minimum, the inlet pipe modifications will include (2) 6" R.W. gate valves & boxes, (1) 6" DIMJ tee, (1) 6" line stop, a repair of the existing inlet piping and associated new piping. The modifications to the existing influent pipe shall also include pumping down the contents of the temporary treatment cell, including as much of the sludge accumulation as practical, to the remaining facultative lagoon.

Alternate methods of construction for the specified temporary treatment cell construction shall be subject to the approval of the Village of Viola and the Engineer.

The price for the above described work shall be included in the lump sum price for the S.T.P. Upgrade work.

Please acknowledge Addendum #2 on page 1 of Bid Form of Proposal. This Addendum will be sent by Fax and available to download on our website www.missman.com under "Out to Bid".

Respectfully submitted,

MISSMAN, STANLEY & ASSOCIATES, PROF. CORP.

By


Scott Kammerman